

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

**Certificate of conformity of the factory production control
0432-CPR-00593-01 (EN)**

Version 01

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

double-wall chimney system
with 30 mm heat insulation (105 kg/m³ and 170 - 190 kg/m³)
and flue liners made of stainless steel: 1.4404 / 1.4571

"Specflue DW30"

(for a detailed product description see annex 1 of this certificate)

placed on the market under the name or trade mark of

Specflue Ltd

8 Curzon Road, Chilton Industrial Estate
Sudbury, Suffolk CO10 2XW / United Kingdom

and produced in the manufacturing plant(s)

HW01


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 1856-1:2009under **system 2+** are applied and that**the factory production control is assessed to be in conformity
with the applicable requirements**

This certificate was first issued on 19.06.2019 and will remain valid until 18.06.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 19.06.2019

by order



Dipl.-Ing. Hönig

Head of Certification Body (Dept. 21)

This Certificate consists of 1 page and 1 annex(es).

The original of this document was issued in German language.

In case of doubt only the German version is valid.



Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Vom Hersteller erklärte Eigenschaften für / Declared conditions by the manufacturer for:

	Art der Abgasanlage/ Leitung <i>type of chimney/ flue pipe</i>	Harmonisierte Norm standard	Produktbeschreibung <i>Product description</i>
01	<p>"Specflue DW30" Model 1, 1A doppelwandige Systemabgasanlage mit Wärmedämmung / <i>double wall system chimney with heat insulation</i></p> <p>Innenrohr / <i>inner pipe</i>: 1.4404 / 1.4571 Wanddicke / <i>wall thickness</i>: ≥ 0,5 mm (-10 %) Wärmedämmung/<i>heat insulation</i>: 30 mm, (Formteile/Längenelemente: 105 kg/m³ (-0/+30 %) <i>fittings/ length</i>) (Längenelemente/<i>length</i>): 170-190 kg/m³; Außenrohr / <i>outer pipe</i>: 1.4509; 1.4301 Wanddicke / <i>wall thickness</i>: ≥ 0,5 mm (-10 %)</p>	EN 1856-1:2009	<p>T600 – N1 – W – V2 – L50050 – G(60) T600 – N1 – D – V2 – L50050 – G(60)</p> <p>DN 120/180 – 300/360</p> <p>Abstand zu brennbaren Bauteilen:/ <i>distance to combustibles</i>: 60mm (geprüft mit Firestop in Übereinstimmung mit den britischen Anforderungen/ <i>tested with firestop in accordance with the british requirements</i>)</p>
02	<p>"Specflue DW30" Model 2,2A doppelwandige Systemabgasanlage mit Wärmedämmung / <i>double wall system chimney with heat insulation</i></p> <p>Innenrohr / <i>inner pipe</i>: 1.4404 / 1.4571 Wanddicke / <i>wall thickness</i>: ≥ 0,5 mm (-10 %) Wärmedämmung/<i>heat insulation</i>: 30 mm, (Formteile/Längenelemente: 105 kg/m³ (-0/+30 %) <i>fittings/ length</i>) (Längenelemente/<i>length</i>): 170-190 kg/m³; Außenrohr / <i>outer pipe</i>: 1.4509; 1.4301 Wanddicke / <i>wall thickness</i>: ≥ 0,5 mm (-10 %)</p>	EN 1856-1:2009	<p>T600 – N1 – W – V2 – L50050 – G(50) T600 – N1 – D – V2 – L50050 – G(50)</p> <p>DN 120/180 – 300/360</p> <p>Abstand zu brennbaren Bauteilen:/ <i>distance to combustibles</i>: 50mm (geprüft mit vollständig hinterlüfteten Deckendurchführungen / <i>tested in fully ventilated floor penetrations</i>)</p>